

# 6.21 [157.8] REMOVAL OF LID REMOVAL OF LID





### NAMEPLATE





CI I Div 1, Grps C-D; CI I Div 2, Grps A-D; Type 4X Ex d IIIB + H<sub>2</sub> T6 Gb; IP65 -50°C  $\leq$  Ta  $\leq$  60°C SIRA 07ATEX1273X IECEx SIR 07.0093X Electrical Rating: 250mA/24VDC, 120VAC PILOT: 24 VDC

Model #:



TopWorx 3300 Fern Valley Road Louisville, KY 40213 USA www.topworx.com Serial #:





### **MODEL NUMBER**

## DXS-ES1GM4B162T

### PRODUCT LINE

### Switchbox DXP and DXS

### **SPECIFICATIONS**

Enclosure 316 stainless steel

 $\begin{array}{lll} Bus/Sensor & ESD/PST \ module \ w/ \ GO^{TM} \ Switch \\ Area \ Classification & Explosion \ proof \ / \ flame \ proof \\ Visual \ Display & Standard \ 90^\circ \ Green \ OPEN, \ Red \ CLOSED \\ \end{array}$ 

Shaft NAMUR 316 stainless steel

Conduit Entries (2)  $\frac{3}{4}$  NPT, (2)  $\frac{1}{2}$  NPT

O-Rings Buna-N Pilot (1) 24Vo

(1) 24Vdc pilot, fail open/closed


 $\begin{array}{lll} \mbox{Spool Valve} & \mbox{316 stainless steel} \\ \mbox{Valve Cv} & \mbox{0.86 Cv (1/4" NPT Ports)} \end{array}$ 

Manual Override Partial stroke test button w/ lockable cover

Regional Certification No regional certification

N Switch No N Switch

### WIRING DIAGRAM



Current as of April 12, 2017 – Subject to change without notice.

# **TOPWORX**

3300 Fern Valley Road Louisville, KY 40213 (502)969-8000 PH (502)969-5911 FAX www.topworx.com

