



50

CL I DIV 2, GRPS A,B,C,D; CL II DIV 2, GRPS F,G; CI III; ELECTRICAL RATING: 120VAC/10A, 24VDC/3A RESISTIVE; 600VAC MAX LEAD SEAL IS REQUIRED WITHIN 18" OF ENCLOSURE.

Model #:

Serial #:

81-20526-A3

GOTM Switch Model 81

Model
Contact Form
DPDT (Form CC)
Sensing Range
Outlet Position
Enclosure Material
Area Classification
Wiring Options
Regional Certification

81 Model
DPDT (Form CC)
Approx. 1/4" end sensing
Bottom of enclosure
Stainless steel
CSA/FM Cl 1, Div 2
6ft PVC lead wires
no regional certification

Custom field

Current as of April 20, 2018 - Subject to change without notice.